



IECEX Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification System for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.: **IECEX BVS 17.0091X** Page 1 of 4 Certificate history:
Status: **Current** Issue No: 1 Issue 0 (2017-12-01)
Date of Issue: 2021-08-20
Applicant: **RECKMANN GMBH**
Werkzeugstr. 19 - 23
58093 Hagen
Germany
Equipment: **Temperature sensors type see general product information**
Optional accessory:
Type of Protection: **Equipment protection by intrinsic safety "i", Equipment with Equipment Protection Level (EPL) Ga**
Marking: See Annex

Approved for issue on behalf of the IECEx
Certification Body:

Ralf Leiendecker

Position:

Deputy Head of Certification Body

Signature:
(for printed version)

Date:

20.08.2021

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting www.iecex.com or use of this QR Code.



Certificate issued by:

DEKRA Testing and Certification GmbH
Certification Body
Dinnendahlstrasse 9
44809 Bochum
Germany

 **DEKRA**
On the safe side.



IECEX Certificate of Conformity

Certificate No.: **IECEX BVS 17.0091X**

Page 2 of 4

Date of issue: 2021-08-20

Issue No: 1

Manufacturer: **RECKMANN GMBH**
Werkzeugstr. 19 - 23
58093 Hagen
Germany

Additional
manufacturing
locations:

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEX Quality system requirements. This certificate is granted subject to the conditions as set out in IECEX Scheme Rules, IECEX 02 and Operational Documents as amended

STANDARDS :

The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

IEC 60079-0:2017 Explosive atmospheres - Part 0: Equipment - General requirements
Edition:7.0

IEC 60079-11:2011 Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"
Edition:6.0

IEC 60079-26:2021-02 Explosive atmospheres - Part 26: Equipment with Separation Elements or combined Levels of Protection
Edition:4.0

This Certificate **does not** indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Report:

DE/BVS/ExTR17.0086/01

Quality Assessment Report:

DE/BVS/QAR14.0005/07



IECEX Certificate of Conformity

Certificate No.: **IECEX BVS 17.0091X**

Page 3 of 4

Date of issue: 2021-08-20

Issue No: 1

EQUIPMENT:

Equipment and systems covered by this Certificate are as follows:

Type code

See Annex

Description

The temperature sensors respectively the measuring inserts respectively the cable sensors serve the function of recording process temperatures in areas of explosion hazards.

The sensor elements (resistance elements or thermocouples) are placed on the tip of a metal tube with a length of up to 8000 mm. Up to 2 sensor elements are installed in the temperature sensors respectively the measuring inserts respectively the cable sensors, each in 2-, 3- or 4-wire-technology.

The temperature sensors respectively the measuring inserts respectively the cable sensors have to be connected only to one intrinsically safe circuit.

Ratings

See Annex

SPECIFIC CONDITIONS OF USE: YES as shown below:

See Annex



IECEX Certificate of Conformity

Certificate No.: **IECEX BVS 17.0091X**

Page 4 of 4

Date of issue: 2021-08-20

Issue No: 1

DETAILS OF CERTIFICATE CHANGES (for issues 1 and above)

The temperature sensors were tested in accordance to the standards listed on page 1.

Annex:

[BVS_17_0091x_Reckmann_Annex1_1.pdf](#)



IECEX Certificate of Conformity



Certificate No.: IECEx BVS 17.0091X Issue 1
Annex
Page 1 of 14

General product information:

Temperature sensors type	Marking
BWR15-****-*-*	Ex ia I Mb
WR15-B****-*, WR15-C****-*, WR15-D****-*, WR15-E****-*, WR15-F****-*, WR15-G****-*, WR15-H****-*, WR15-J****-*, TR15-B****-*, TR15-C****-*, TR15-D****-*, TR15-E****-*, TR15-F****-*, TR15-G****-*, TR15-H****-*, TR15-J****-*	Ex ia IIC T1 ... T6 Ga/Gb Ex ia IIIC T135°C Da/Db
WR15-K****-*, WR15-L****-*, WR15-CX****-*, WR15-EX****-*, TR15-K****-*, TR15-L****-*, TR15-CX****-*, TR15-EX****-*, WR14-J-****-*, TR14-J-****-*, WR14-X-****-*, TR14-X-****-*	Ex ia IIC T1 ... T6 Gb Ex ia IIIC T135°C Db
WR14-O*-****, TR14-O*-****, WR14-P*-****, TR14-P*-****, WR14-M*-***, TR14-M*-***, RKW-8-*****, RKW-9-*****	Ex ia IIC T1 ... T6 Ga Ex ia IIIC T135°C Da



IECEX Certificate of Conformity



Certificate No.: IECEx BVS 17.0091X Issue 1
Annex
 Page 2 of 14

Type code:

Temperature sensors for use in potentially explosive atmospheres (mining)							
Resistance temperature detector	BWR15	-*	*	*	*	-*	-*
Protection fitting type							
Model 2 with coupling nut		B					
Model 8 (2GoH)		C					
Model 2G		D					
Number of sensors							
Single			1				
Double			2				
Sensor							
PT100			PT100				
PT1000			PT1000				
Type R14 measuring insert							
R144				D			
Measuring insert diameter							
3.00 mm					300		
6.00 mm					600		
8.00 mm					800		
Cable connection							
Cable gland							X
M12 built-in plug VA							A
M12 built-in socket VA							B



IECEx Certificate of Conformity



Certificate No.: IECEx BVS 17.0091X Issue 1
Annex
Page 4 of 14

Measuring inserts for use in potentially explosive gas or dust atmospheres							
Resistance temperature detector	WR14	-*	-*	*	*	*	-*
Mineral insulated thermocouple	TR14	-*	-*	*	*	*	-*
Measuring insert type							
Model B		J					
without connection head		X					
Model R144			D				
Model R149 free-ended			Q				
Measuring insert diameter							
3.00 mm				300			
6.00 mm				600			
8.00 mm				800			
Number of sensors							
Single					1		
Double					2		
Sensor							
PT100	WR14					PT100	
PT1000	WR14					PT1000	
Ni100	WR14					Ni100	
Cu-CuNi type T	TR14					T	
Fe-CuNi type J	TR14					J	
NiCr-CuNi type E	TR14					E	
NiCr-Ni type K	TR14					K	
NiCrSi-NiSi type N	TR14					N	
Pt13%Rh-Pt type R	TR14					R	
Pt10%Rh-Pt type S	TR14					S	
Cable connection							
without (for ME) / cable gland							X
M12 built-in plug							A
M12 built-in socket							B




IECEX Certificate of Conformity



Certificate No.: IECEx BVS 17.0091X Issue 1
Annex
 Page 5 of 14

Temperature sensors with cable (Lmax = 50 m) for use in potentially explosive gas or dust atmospheres							
Resistance temperature detector	WR14	-*	*	-*	*	*	*
Mineral insulated thermocouple	TR14	-*	*	-*	*	*	*
Measuring insert type							
Model D		O					
Model DST (D with plug connector)		P					
Measuring insert diameter							
1.50 mm (only single sensor)			150				
2.00 mm (only single sensor)			200				
3.00 mm			300				
6.00 mm			600				
8.00 mm			800				
Number of sensors							
Single				1			
Double				2			
Sensor							
PT100	WR14				PT100		
PT1000	WR14				PT1000		
Ni100	WR14				Ni100		
Cu-CuNi type T	TR14				T		
Fe-CuNi type J	TR14				J		
NiCr-CuNi type E	TR14				E		
NiCr-Ni type K	TR14				K		
NiCrSi-NiSi type N	TR14				N		
Pt13%Rh-Pt type R	TR14				R		
Pt10%Rh-Pt type S	TR14				S		
Connection cables							
PVC/PVC						A	
PVC/shielding/PVC						B	
Glass silk/silicone						C	
Glass silk/silicone/glass silk/shielding						D	
Silicone/silicone/FEP						E	
Siliconeon/silicone/shielding/FEP						F	
Cable connection							
Free-ended cables							X
Mini compensation plug connector							A
Lemo plug connector							B
M12 / M8 plug connector							C




IECEx Certificate of Conformity



Certificate No.: IECEx BVS 17.0091X Issue 1
Annex
 Page 6 of 14

Temperature sensors with plug connector for use in potentially explosive gas or dust atmospheres						
Resistance temperature detector	WR14	_*	*	_*	*	*
Mineral insulated thermocouple	TR14	_*	*	_*	*	*
Measuring insert type						
Model L		M				
Measuring insert diameter						
1.50 mm (only single sensor)			150			
2.00 mm (only single sensor)			200			
3.00 mm			300			
6.00 mm (only with Lemo plug connector)			600			
8.00 mm (only with Lemo plug connector)			800			
Number of sensors						
Single				1		
Double				2		
Sensor						
PT100	WR14				PT100	
PT1000	WR14				PT1000	
Ni100	WR14				Ni100	
Cu-CuNi type T	TR14				T	
Fe-CuNi type J	TR14				J	
NiCr-CuNi type E	TR14				E	
NiCr-Ni type K	TR14				K	
NiCrSi-NiSi type N	TR14				N	
Pt13%Rh-Pt type R	TR14				R	
Pt10%Rh-Pt type S	TR14				S	
Cable connection						
Mini compensation plug connector						A
Lemo plug connector						B



IECEx Certificate of Conformity



Certificate No.: IECEx BVS 17.0091X Issue 1
Annex
 Page 7 of 14

Cable sensors (Lmax = 50 m) for use in potentially explosive gas or dust atmospheres							
Resistance temperature detector	RKW	-*	-*	-*	*	*	*
Cable sensor type							
without pipe clip		8					
with pipe clip		9					
Sensor diameter							
3.00 mm			300				
4.00 mm			400				
6.00 mm			600				
8.00 mm			800				
Number of sensors							
Single				1			
Double				2			
Sensor							
PT100					PT100		
PT1000					PT1000		
Ni100					Ni100		
Connection cables							
PVC/PVC						A	
PVC/shielding/PVC						B	
Glass silk/silicone						C	
Glass silk/silicone/glass silk/shielding						D	
Silicone/silicone/FEP						E	
Silicone/silicone/shielding/FEP						F	
Cable connection							
Free-ended cables							X
Lemo plug connectors							B
M12 / M8 plug connectors							C

Ratings

The temperature sensors respectively the measuring inserts respectively the cable sensors have to be connected only to one intrinsically safe circuit independent of the number of wires.

Minimum permissible process temperature for all sensors: -40 °C

1 Temperature sensor type BWR15-****-*-* , Ex ia I Mb (mining)

Maximum input voltage	U _i	DC	15	V
Maximum input current	I _i		100	mA
Maximum input power	P _i		see table	
Maximum internal capacitance	C _i		negligible	
Maximum internal inductance	L _i		negligible	



IECEX Certificate of Conformity



Certificate No.: IECEx BVS 17.0091X Issue 1
Annex
Page 8 of 14

Permissible process temperature in °C depends on P_i and the measuring insert diameter

type	20 mW	50 mW	250 mW	500 mW	750 mW
BWR15-****-300-*	146	140	104	58	12
BWR15-****-600-*	147	144	123	97	71
BWR15-****-800-*	147	144	123	97	71

Ambient temperature range of the connection head: -40 °C up to +80 °C

- 2 Temperature sensor type WR15-B***-**-*, WR15-C***-**-*, WR15-D***-**-*, WR15-E***-**-*, WR15-F***-**-*, WR15-G***-**-*, WR15-H***-**-*, WR15-J***-**-*; TR15-B***-**-*, TR15-C***-**-*, TR15-D***-**-*, TR15-E***-**-*, TR15-F***-**-*, TR15-G***-**-*, TR15-H***-**-*, TR15-J***-**-*

Ex ia IIC T1 ... T6 Ga/Gb (with partition wall)

Maximum input voltage	U_i	DC	30	V
Maximum input current	I_i		100	mA
Maximum input power	P_i		see table	
Maximum internal capacitance	C_i		negligible	
Maximum internal inductance	L_i		negligible	

Permissible process temperature in °C depends on P_i and the temperature class.

For types WR15 and measuring insert diameter 3 mm:


Temperature class	20 mW	50 mW	250 mW	500 mW	750 mW
T1	438	435	417	394	371
T2	288	285	267	244	221
T3	193	190	172	149	126
T4	128	125	107	84	61
T5	93	90	72	49	26
T6	78	75	57	34	11

For types WR15 and measuring insert diameter 6 mm and 8 mm:

Temperature class	20 mW	50 mW	250 mW	500 mW	750 mW
T1	439	437	427	414	401
T2	289	287	277	264	251
T3	194	192	182	169	156
T4	129	127	117	104	91
T5	94	92	82	69	56
T6	79	77	67	54	41

For types TR15 and measuring insert diameter 3 mm, 6 mm and 8 mm:

Temperature class	750 mW
T1	435
T2	285
T3	190
T4	125
T5	90
T6	75



IECEX Certificate of Conformity



Certificate No.: IECEx BVS 17.0091X Issue 1

Annex

Page 9 of 14

Ambient temperature range of the connection head: -40 °C up to +80 °C for T5 ... T6
-40 °C up to +100 °C for T1 ... T4

Note: If replacing the cable gland with a built-in M12 plug connector,
the ambient temperature range is reduced to -40 °C to +80 °C for T1...T6.

Ex ia IIIC T135°C Da/Db (with partition wall)

Maximum input voltage	U_i	DC	30	V
Maximum input current	I_i		100	mA
Maximum input power	P_i		see table	
Maximum internal capacitance	C_i		negligible	
Maximum internal inductance	L_i		negligible	

Permissible ambient-/process temperature range in °C depend on P_i

P_i	Ambient-/Process temperature range
750 mW	-40 °C up to +40 °C
650 mW	-40 °C up to +70 °C
550 mW	-40 °C up to +100 °C

Note: If replacing the cable gland with a built-in M12 plug connector,
the ambient temperature range is reduced to -40 °C to +80 °C.

- 3 Temperature sensor type WR15-K***-**-*, WR15-L***-**-*, WR15-CX***-**-*, WR15-EX***-**-*, TR15-K***-**-*, TR15-L***-**-*, TR15-CX***-**-*, TR15-EX***-**-*, and measuring insert Typ WR14-J-****-*, TR14-J-****-*, WR14-X-****-*, TR14-X-****-*

Ex ia IIC T1 ... T6 Gb

Maximum input voltage	U_i	DC	30	V
Maximum input current	I_i		100	mA
Maximum input power	P_i		see table	
Maximum internal capacitance	C_i		negligible	
Maximum internal inductance	L_i		negligible	

Permissible process temperature in °C depends on P_i and the temperature class.


For types WR15 / WR14 with measuring insert diameter 3 mm:

Temperature class	20 mW	50 mW	250 mW	500 mW	750 mW
T1	436	430	394	348	302
T2	286	280	244	198	152
T3	191	185	149	103	57
T4	126	120	84	38	/
T5	91	85	49	3	/
T6	76	70	34	/	/

For types WR15 / WR14 with measuring insert diameter 6 mm and 8 mm:

Temperature class	20 mW	50 mW	250 mW	500 mW	750 mW
T1	437	434	413	387	361
T2	287	284	263	237	211
T3	192	189	168	142	116
T4	127	124	103	77	51
T5	92	89	68	42	16
T6	77	74	53	27	1

For types TR15 / TR14 with measuring insert diameter 3 mm, 6 mm and 8 mm:



IECEX Certificate of Conformity



Certificate No.: **IECEX BVS 17.0091X Issue 1**

Annex
Page 10 of 14

Temperature class	750 mW
T1	430
T2	280
T3	185
T4	120
T5	85
T6	70

Ambient temperature range of the connection head: -40 °C up to +80 °C for T5 ... T6
-40 °C up to +100 °C for T1 ... T4

Note: If replacing the cable gland with a built-in M12 plug connector,
the ambient temperature range is reduced to -40 °C to +80 °C for T1...T6.

Ex ia IIC T135°C Db

Maximum input voltage	U_i	DC	30	V
Maximum input current	I_i		100	mA
Maximum input power	P_i		see table	
Maximum internal capacitance	C_i		negligible	
Maximum internal inductance	L_i		negligible	

Permissible ambient-/process temperature range in °C depend on P_i

P_i	Ambient-/Process temperature range
750 mW	-40 °C up to +40 °C
650 mW	-40 °C up to +70 °C
550 mW	-40 °C up to +100 °C

Note: If replacing the cable gland with a built-in M12 plug connector,
the ambient temperature range is reduced to -40 °C to +80 °C.

- 4 Temperature sensor type WR14-O*-****, TR14-O*-****, WR14-P*-****, TR14-P*-****,
WR14-M*-***, TR14-M*-***


Ex ia IIC T1 ... T6 Ga

Maximum input voltage	U_i	DC	30	V
Maximum input current	I_i		100	mA
Maximum input power	P_i		see table	
For type WR14-M*-***, TR14-M*-***:				
Maximum internal capacitance	C_i		negligible	
Maximum internal inductance	L_i		negligible	
For type WR14-O*-****, TR14-O*-****, WR14-P*-****, TR14-P*-**** (cable length max. 50 m)				
Maximum internal capacitance	C_i		0.2 nF/m	
Maximum internal inductance	L_i		1 µH/m	

Permissible process temperature in °C depends on P_i and the temperature class.

For types WR14 and measuring insert diameter 1.5 mm and 2 mm:

Temperature class	20 mW	50 mW	250 mW	500 mW	750 mW
T1	434	426	369	300	229
T2	284	276	219	150	79
T3	189	181	124	55	/
T4	124	116	59	/	/
T5	89	81	24	/	/
T6	74	66	9	/	/



IECEX Certificate of Conformity



Certificate No.: IECEx BVS 17.0091X Issue 1
Annex
Page 11 of 14

For types WR14 and measuring insert diameter 3 mm:

Temperature class	20 mW	50 mW	250 mW	500 mW	750 mW
T1	436	430	394	348	302
T2	286	280	244	198	152
T3	191	185	149	103	57
T4	126	120	84	38	/
T5	91	85	49	3	/
T6	76	70	34	/	/

For types WR14 and measuring insert diameter 6 mm and 8 mm:

Temperature class	20 mW	50 mW	250 mW	500 mW	750 mW
T1	437	434	413	387	361
T2	287	284	263	237	211
T3	192	189	168	142	116
T4	127	124	103	77	51
T5	92	89	68	42	16
T6	77	74	53	27	1

For types TR14 and measuring insert diameter 1.5 mm, 2 mm, 3 mm, 6 mm and 8 mm:

Temperature class	750 mW
T1	430
T2	280
T3	185
T4	120
T5	85
T6	70

Ambient temperature range of the sleeve, connection cable and plug connector for type WR14-O*-****, TR14-O*-****, WR14-P*-****, TR14-P*-****:

-40 °C up to +75 °C for T5 ... T6

-40 °C up to +100 °C for T1 ... T4

Ambient temperature range of the plug connector for type WR14-M*-***, TR14-M*-***:

-40 °C up to +80 °C for T5 ... T6

-40 °C up to +100 °C for T1 ... T4



IECEX Certificate of Conformity



Certificate No.: IECEx BVS 17.0091X Issue 1
Annex
Page 12 of 14

Ex ia IIIC T135°C Da

Maximum input voltage	U_i	DC	30	V
Maximum input current	I_i		100	mA
Maximum input power	P_i		see table	
For type WR14-M*-***, TR14-M*-***:				
Maximum internal capacitance	C_i		negligible	
Maximum internal inductance	L_i		negligible	
For type WR14-O*-****, TR14-O*-****, WR14-P*-****, TR14-P*-**** (cable length max. 50 m)				
Maximum internal capacitance	C_i		0.2 nF/m	
Maximum internal inductance	L_i		1 µH/m	

Permissible ambient-/process temperature range in °C depends on P_i

P_i	Ambient-/Process temperature range
750 mW	-40 °C up to +40 °C
650 mW	-40 °C up to +70 °C
550 mW	-40 °C up to +100 °C

5 Cable sensor type RKW-8*-****, RKW-9*-****

Ex ia IIC T1 ... T6 Ga

Maximum input voltage	U_i	DC	30	V
Maximum input current	I_i		100	mA
Maximum input power	P_i		see table	
(cable length max. 50 m)				
Maximum internal capacitance	C_i		0.2 nF/m	
Maximum internal inductance	L_i		1 µH/m	

Permissible process temperature in °C depends on P_i and the temperature class.


For types RKW and sensor diameter 3 mm, 4 mm, 6 mm und 8 mm:

Temperature class	20 mW	50 mW	250 mW	500 mW	750 mW
T1	434	425	367	294	221
T2	284	275	217	144	71
T3	184	175	117	44	/
T4	124	115	57	/	/
T5	89	80	22	/	/
T6	74	65	7	/	/

Ambient temperature range of the connection cable and plug connector for type RKW-8*-****, RKW-9*-****:

-40 °C bis +75 °C für T5 ... T6

-40 °C bis +100 °C für T1 ... T4



IECEX Certificate of Conformity



Certificate No.: IECEx BVS 17.0091X Issue 1
Annex
Page 13 of 14

Ex ia IIIC T135°C Da

Maximum input voltage	U_i	DC	30	V
Maximum input current	I_i		100	mA
Maximum input power	P_i		see table	
(cable length max. 50m)				
Maximum internal capacitance	C_i		0.2	nF/m
Maximum internal inductance	L_i		1	µH/m

Permissible ambient-/process temperature range in °C depend on P_i

P_i	Ambient-/Process temperature range
750 mW	-40 °C up to +40 °C
650 mW	-40 °C up to +70 °C
550 mW	-40 °C up to +100 °C

Specific Conditions of Use:

- The temperature sensors respectively the measuring inserts respectively the cable sensors are suitable for use within the following ambient temperature range: see ratings

In case that process temperatures measured deviate from these parameters, the ambient temperature range and the temperature class defined refer only to the connection head or the sleeve, connection cable and plug connector depending on type. The impact of the process temperature on the temperature of the neck tube has to be considered separately in use of the temperature sensors respectively the measuring inserts respectively the cable sensors.

Appropriate measures, e.g. an adequate choice of neck tube length, shall assure that, dependent on type, the temperature of the connection head or the sleeve, connection cable and plug connector is decoupled from the process temperature as such.
- The manufacturer's instructions regarding admissible process conditions shall be adhered to.
- For the measuring inserts type WR14-X-****-* and TR14-X-****-* valid:

The measuring insert has to be installed into an enclosure that guarantees at least the type of protection IP20.
The internal wiring has to meet the requirements of clause 6.3.12 of IEC 60079-11:2011.


The installation has to be carried out in a manner that the air gaps between blank parts of intrinsically safe circuits and metallic enclosure parts are at least 3 mm.
- For the sensors with marking Ex ia IIC T1 ... T6 Ga/Gb and Ex ia IIIC T135°C Da/Db valid:

The separation wall (stainless steel tube) has a wall thickness ≥ 1 mm.

The installation into a separation wall between areas with Ga/Gb - resp. Da/Db - requirements has to be done in such a way, that all metallic parts are conductively connected to the metal container wall; or, if the container is made of plastic, that all insulated metal parts are connected to equipotential bonding.

The sensors have to be installed into the separation wall with standardized connections. At the place of installation, technical tightness has to be ensured.
- For the sensors type WR14-O*-****, TR14-O*-****, WR14-P*-****, TR14-P*-****, RKW-8*-****, RKW-9*-**** valid:

In gas-explosive areas, the sensors have to be installed in such a way, that electrostatic charging is excluded.



IECEX Certificate of Conformity



Certificate No.: IECEx BVS 17.0091X Issue 1
Annex
Page 14 of 14

- 6 For the sensors type WR14-O*-****, TR14-O*-****, WR14-P*-****, TR14-P*-****, WR14-M*-***, TR14-M*-***, RKW-8*-****, RKW-9*-**** valid:

The metallic parts of the sensors have to be included into the potential equalization.

- 7 The intrinsically safe circuit of the sensors with diameter 3 mm and more than 4 internal wires, sensors with diameter < 3 mm and sensors with diameter > 3 mm and more than 6 internal wires has to be regarded as earthed.
Along to the intrinsically safe circuit potential equalization has to be provided.